

**Public Notice Mandatory Language for Monitoring and Reporting Violation
Operational Evaluation Report**

The MAXWELL WSC water system PWS ID TX0280003 has violated the monitoring and reporting requirements set by Texas Commission on Environmental Quality (TCEQ) in Chapter 30, Section §290, Subchapter F. Public water systems in exceedance of an operational evaluation level are required to conduct an evaluation of their source water, treatment and distribution operations and submit a report of their findings to the TCEQ.

We failed to conduct an operational evaluation and/or submit a report to the TCEQ.

This/These violation(s) occurred in the monitoring period(s) quarter three 2021.

We are taking the following actions to address this issue:

We are currently still disinfecting with free chlorine. We are trying to manage water age and turnover tanks more often. We also will soon start blending our Edwards ground water with the CRWA surface water, to try and help bring down the TTHM concentration in the distribution system.

Please share this information with all other people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact Justin Ivicic at (512) 357 - 6253.

Posted/Delivered on: 3/31/2022
